

पत्रांक 4035 / 10.08.2022

निदेशक-सह-राज्य अग्निशमन पदाधिकारी का कार्यालय, बिहार, पटना।

पटना, दिनांक 17/1/2023

सेवा में

केन्द्रीय विद्यालय,
झांझा, जमुई।


विषय-

अग्नि अकैक्षण घमाण-पत्र के संबंध में।

महाशय,

उपर्युक्त विषय के संबंध में कहना है, कि केन्द्रीय विद्यालय, झांझा, जमुई का अनुमंडल अग्निशामालय पदाधिकारी, जमुई द्वारा दिनांक 25.11.2022 को अग्नि अकैक्षण किया गया है। पुनः दिनांक 08.02.2023 को जाँच कर अनुपालन प्रतिवेदन समर्पित है। राष्ट्रीय भवन संहिता 2016 एवं बिहार अग्निशमन सेवा नियमावली 2021 के तहत लगाये गये सभी अग्निशमन यंत्र एवं अन्य अग्नि सुरक्षा उपकरण पर्याप्त प्रतीत होते हैं।

अतः उक्त संस्थान का पुनः दिनांक 26.12.2023 को अग्नि अकैक्षण कराना सुनिश्चित करें।



निदेशक-सह-राज्य अग्निशमन पदाधिकारी,
बिहार, पटना।

झापांक 4035 / पटना, दिनांक 16/1/2023

निदेशक-सह-राज्य अग्निशमन पदाधिकारी का कार्यालय, बिहार, पटना।

प्रतिलिपि- 01. जिला समादेष्टा-सह-जिला अग्निशमन पदाधिकारी, जमुई को सूचनार्थ एवं आवश्यक क्रियार्थ प्रेषित।

02. अनुमंडल अग्निशामालय पदाधिकारी, जमुई को सूचनार्थ एवं आवश्यक क्रियार्थ प्रेषित।


निदेशक-सह-राज्य अग्निशमन पदाधिकारी,
बिहार, पटना।



P.H. DIVISION, JAMUI
Test report of Water Quality Raw Water

Agency name- Kendriya Vidyalaya Jhajha
Sample Collected by- School
Date of Sampling:-05.02.2023

Physico-Chemical and Bacteriological Parameters					PH	Turb	TDS	EC	TH	Ca	Mg	Cl	F	NO3	Alkali	T.Coli	Remarks
Unit					-	NTU	mg/l	ymho/cm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	MPN/100 ml	
Permissible Limit* in absence of alternate source					6.5-8.5	1.00	500	-	200	75	30	250	1.00	45	200	YES/NO	
Sl. No	Block	Panchyat	Habitation	Ward No	6	7	8	9	10	11	12	13	14	15	16	17	18
1	Jhajha	Jhajha	Kendriya Vidyalaya Jhajha	-	7.0	0.47	324	498	124	68	14	236	0.48	12	172	NO	Safe

A. P. Singh
64/03/2023
Chemist/Lab Assistant
P.H. Division, Jamui



केन्द्रीय माध्यमिक शिक्षा बोर्ड
Central Board of Secondary Education
संबद्धता - School Affiliation Re-Engineered Automation System (SARAS) 4.0

Details OF SCHOOL AFFILIATED TO
Central Board of Secondary Education

Details Of The School Filled up AFFILIATION/OASIS

Name of Institution	KENDRIYA VIDYALAYA JHAJHA
Affiliation Number	300056
State	BIHAR
District	JAMUI
Postal Address	KENDRIYA VIDYALAYA JHAJHA RAILWAY COLONY JHAJHA
Pin Code	811308
Website	jhajha.kvs.ac.in
Year of Foundation	2015
Date of First Opening of School	7/20/2015 12:00:00 AM
Name of Principal/ Head of Institution	SACHIDANAD TIWARI
Gender	Male
Principal's Educational/Professional Qualifications:	PHD
No of Experience (in Years):	
	Administrative: 6
	Teaching: 15
Status of The School	Secondary Level
Affiliation Period	From : 01/04/2023 To : 31/03/2028
Name of Trust/ Society/ Managing Committee	KVS, New Delhi